

IBP Fraunhofer Institute for Structural Physics  
Stuttgart, 09.06.2016  
Test report No. P5-157/2016  
**Heat Transition Coefficient**



tested, DIN EN ISO 12567-1:2010-12 (heater box process)

## **Wellhöfer Attic Stairs**

(Type with additional feature thermal protection WS4D)

**Heat Transition Coefficient = 0.58**

**U-value;** W/(m<sup>2</sup>K)

- > **Component tested insulation value**  
for complete attic stairs
- > **Significantly better** than the requirements  
of EnEV with regard windows  
(German Energy Saving Ordinance;  $U \leq 1.3$ )