

Extract from the TÜV Rheinland LGA Products
test report 02.11.2015

Test report no. 21242493001

VOC emissions test



tested, DIN EN ISO 16000, according to the approval regulations for
the health-related assessment of construction products, CEN/TS 16516

Wellhöfer Attic Stairs

28-day test of the **sum total of volatile organic compounds (TVOC)** and **formaldehyde (HCHO)**; target values for harmlessness as specified by the Sentinel Haus Institut.

Emission	Test results	Harmless value according to Sentinel Haus Institut
TVOC:	35 µg/m ³	<300 µg/m ³
HCHO:	1,5 µg/m ³	<24 µg/m ³

- > The emissions value of the attic stairs is **over 9x better than the value which is considered to be harmless** as required by the Sentinel Haus Institut.
- > The formaldehyde value of the attic stairs is **over 16x better than the value which is considered to be harmless** as required by the Sentinel Haus Institut.

For over 20 years, Ecological Building Systems has been at the forefront of environmental and sustainable building products supplying a range of innovative airtightness solutions and natural insulations backed up with expert technical support.

As product suppliers in the UK and Ireland, we're happy to assist you with your projects and have expert technical and sales advice on hand.



Call us

Great Britain +44 (0)1228 711511

Ireland +353 46 9432104



Email us

info@ecologicalbuildingsystems.com



Find us

Great Britain Ecological Building Systems UK Ltd.,
Cardewlees, Carlisle, Cumbria, CA5 6LF,
United Kingdom

Ireland Ecological Building Systems Ltd.,
Main Street, Athboy. Co. Meath, C15 Y678,
Republic of Ireland